

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0476:118 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Harrington Signal Inc., 2519 4th Avenue, Moline, IL 61265
Contact: Andrew Keller (309) 762-0731

DESIGN: Model PT25W24 POWERTONE system tone module. The system consists of a PowerTone module, Model PTBD, one or more Model 5130-107-01 alarm signal mini-modules, Model PTPLATE plate kit, board insulator, mounting hardware, adhesive mounting pads, and a surface prep kit. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as a tone module for use with separately listed compatible control unit or auxiliary power supply. The system must be mounted within a Model ULFB1, ULFB2 or ULFB3 enclosure. Model 6.34K end-of-line resistor must be used with the speaker output circuits to maintain electrical supervision.

NOTE: Formerly 7300-0811:113 (Transferred from Federal Signal Corp.)

10-08-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 9, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager